

City of Grand Island

Tuesday, July 11, 2006 Council Session

Item G10

#2006-194 - Approving Change Order No. 1 with Chief Construction for Law Enforcement Center

Staff Contact: Steve Lamken

City of Grand Island City Council

Council Agenda Memo

From: Steven Lamken, Police Chief

Meeting: July 11, 2006

Subject: Change Order #1 Law Enforcement Center

Item #'s: G-10

Presenter(s): Steven Lamken, Police Chief

Background

Due to the high cost of copper wire, Chief Construction has requested to use aluminum electrical feeder conductors for the Law Enforcement Center instead of copper. They have submitted their alternate with all materials to be used. Accepting the alternate results in a savings to the City of \$7,605.00

Discussion

The proposal was reviewed and approved by the project electrical engineer and architect. Accepting Change Order #1 will increase the contingency fund for the project by \$7,605.00 to a total of \$157,605.00.

Alternatives

It appears that the Council has the following alternatives concerning the issue at hand. The Council may:

- 1. Move to approve
- 2. Refer the issue to a Committee
- 3. Postpone the issue to future date
- 4. Take no action on the issue

Recommendation

City Administration recommends that the Council approve Change Order #1 for the Law Enforcement Center.

Sample Motion

Motion to approve Change Order #1 for the construction of the Law Enforcement Center with Chief Construction of Grand Island, Nebraska for a savings to the City in the amount of \$7,605.00.



Change Order

PROJECT (Name and address):	CHANGE ORDER NUMBER: 001	OWNER: 🗵
Grand Island / Hall County Law	DATE: June 16, 2006	ARCHITECT: ⊠
Enforcement Center Grand Island, Nebraska		CONTRACTOR: ⊠
TO CONTRACTOR (Name and address):	ARCHITECT'S PROJECT NUMBER: 0412	
Chief Construction Company	CONTRACT DATE: June 15, 2006	FIELD: 🔲
2107 North South Road Grand Island, Nebraska 68803	CONTRACT FOR: General Construction	OTHER:
THE CONTRACT IS CHANGED AS FOLLOW		
(Include, where applicable, any undispute Re: Proposal Request No. 1	d amount attributable to previously executed C	onstruction Change Directives)
Change electrical feeders from copper to	aluminum.	
(Value of this change: DEDUCT \$ 7,605		
The original Contract Sum was		\$ 7,406,080.00
The net change by previously authorized of	Change Orders	\$ 0.00
The Contract Sum prior to this Change Or The Contract Sum will be decreased by th		\$ <u>7,406,080.00</u>
The new Contract Sum including this Cha	\$ <u>0.00</u> \$ 7,406,080.00	
The Contract Time will be increased by S	ixty Five (65) days.	-
The date of Substantial Completion as of	the date of this Change Order therefore is Augus	st 20, 2007
The original contingency allows	ance included in the contract was	\$ 150,000.00
The net change to the contingen The contingency allowance price	cy allowance by previous Change Orders	\$ 0.00
The contingency allowance will	or to this Change Order was be increased by this Change Order in the amou	\$ 150,000.00 nt of \$ 7,605.00
	including this Change Order will be	\$ 157,605.00
have been authorized by Construction Cha	le changes in the Contract Sum, Contract Time of ange Directive until the cost and time have been is executed to supersede the Construction Char	agreed upon by both the Owner and
NOT VALID UNTIL SIGNED BY THE AR	CHITECT, CONTRACTOR AND OWNER.	
Wilson Estes Police Architecs	Chief Construction Company	City of Grand Island
ARCHITECT (Firm name)	CONTRACTOR (Firm name)	OWNER (Firm name)
5799 Broadmoor, Suite 520, Mission,	2107 North South Road, Grand Island,	100 East 1st Street, Grand Island,
Kansas 66208 ADDRESS	Nebrasky 68803	Nebraska 68801 ADDRESS
Top/ Janat	~777/////	ADDRESS
BY (Signature)	BY (Signabare)	BY (Signature)
Tom Zahn	Grant Ackerman	or (Signature)
(Typed name)	(Typed name)	
6/22/06	(Typed name) 6/24/2006	(~)pariumo)
DATE	DATE	DATE

RESOLUTION 2006-194

WHEREAS, on May 2, 2006, by Resolution 2006-151, the City of Grand Island awarded a bid in the total amount of \$7,406,080.00 (including alternate bids 2 and 3) for the construction of a Law Enforcement Center to Chief Construction Company of Grand Island, Nebraska; and

WHEREAS, due to the cost of copper wire, the contractor has recommended using aluminum instead of copper for the electrical feeder conductors for the project; and

WHEREAS, using aluminum rather than copper wiring for this project will result in a savings of \$7,605.00; and

WHEREAS, such change has been incorporated into Change Order No. 1.

NOW, THEREFORE, BE IT RESOLVED BY THE MAYOR AND COUNCIL OF THE CITY OF GRAND ISLAND, NEBRASKA, that the Mayor be, and hereby is, authorized and directed to execute Change Order No. 1 between the City of Grand Island and Chief Construction Company of Grand Island, Nebraska to allow the use of aluminum rather than copper wiring for the electrical feeder conductors for the Law Enforcement Center.

- - -

Δ	donte	d by	the	City	Council	of the	City	of (Frand	Island	1 1	Nebraska.	Inly	11	2006
$\overline{}$	นบบเต	$\mathbf{u} \mathbf{v} \mathbf{v}$	uic	CILV	Council	OI UIC	CILV	иν	JI anu	usiani	1. 1	incinaska.	Juiv	11.	$\angle (\mathcal{M})(\mathcal{M})$

	Jay Vavricek, Mayor	
Attest:	, , , , , , , , , , , , , , , , , , ,	
RaNae Edwards, City Clerk		