

# **City of Scottsbluff, Nebraska**

**Monday, June 20, 2016**

**Regular Meeting**

## **Item Consent4**

**Council to acknowledge receipt of property damage claims as a result of the June 12, 2016 storm, and forward to the City's Insurance carrier.**

**Staff Contact: Cindy Dickinson, City Clerk**



Please forward ASAP to:

LARM  
League Association of Risk Management  
1335 L Street, Suite 200  
Lincoln, NE 68508

Phone: (402) 742-2600  
Fax: (402) 476-4089  
customerservice@larmpool.org

## Liability Loss Notice

<b>MEMBER</b>			
MEMBER NAME: <b>SCOTTSBLUFF</b>		CONTACT NAME: <b>CINDY DICKINSON</b>	
		PHONE: <b>308.630.6221</b>	
<b>LOSS</b>			
DATE OF LOSS: <b>6-12-2016</b>		TIME OF LOSS: <b>8:00 P.M.</b>	
		DEPARTMENT:	
HAS THIS LOSS BEEN PREVIOUSLY REPORTED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		DATE:	TO WHOM:
LOCATION OF ACCIDENT (INCLUDE CITY & STATE): <b>2701 W. 42ND ST.; 2709 W. 42ND ST.; AND 2717 WEST 42ND ST., SCOTTSBLUFF, NE</b>			
DESCRIPTION OF ACCIDENT (INCLUDE WEATHER CONDITIONS AND OTHER OBSERVATIONS OR CONTRIBUTING FACTORS): <b>EXTREME RAIN STORM CAUSING SEWER TO OVERFLOW, CAUSING DAMAGE TO PROPERTIES.</b>			
CLAIMANT NOTIFICATION OF LOSS TO CITY/ VILLAGE: <input type="checkbox"/> NONE <input type="checkbox"/> AT TIME OF LOSS <input type="checkbox"/> ORAL NOTICE OF LOSS TO: _____ <input checked="" type="checkbox"/> WRITTEN NOTICE HAS BEEN PROVIDED TO CITY / VILLAGE AS SPECIFIED IN THE POLITICAL SUBDIVISION TORT CLAIMS ACT (NE REV. STAT. § 13-905) <b>** ATTACH COPY OF ALL AVAILABLE DOCUMENTS, I.E. POLICE REPORT, ACCIDENT INVESTIGATION REPORTS, CLAIMANT NOTICE.</b>			
<b>CLAIMANT INFORMATION</b>			
NAME AND ADDRESS OF CLAIMANT(S): 1: Gary Hutzal, 4218 Birch Ave., Scottsbluff, NE 69361 (property owner of 2709 W. 42nd St.- Renter: Joel Mauer) 2: David Soule, 2701 W. 42nd St., Scottsbluff, NE 69361 3: Robert Price, 2717 West 42nd St., Scottsbluff		1: Gary Hutzal 308.631.6912 PHONE: 2: David Soule 308.632.4325 3: Robert Price 641-0942 1: Joel Mauer - renter 308.672.1544 OTHER PHONE: 2: 3:	
<b>* BODILY INJURY LOSS *</b>			
DESCRIBE INJURY (IS CLAIMANT A MINOR? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO):		WAS MEDICAL TREATMENT PROVIDED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
		CLINIC/HOSPITAL: _____	
		PHONE: _____	
<b>* PROPERTY DAMAGE LOSS *</b>			
DESCRIBE DAMAGED PROPERTY: Description from owners stated that sewer water backed up into properties and damaged personal items, carpet, furniture, etc.		ESTIMATE OF LOSS: \$ <u>unknown</u>	
		CONTACT PERSON TO VIEW DAMAGED PROPERTY: NAME: <u>owners listed above</u> PHONE: _____	
<b>WITNESSES</b>			
NAME & ADDRESS	MEMBER/EMPLOYEE	BUSINESS PHONE	HOME PHONE
	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
MEMBER COMMENTS / CONCERNS / SPECIAL INSTRUCTIONS (ATTACH A SEPARATE SHEET IF NECESSARY):			
REPORTED BY: Cindy Dickinson, City Clerk		DATE: 6/16/2016	
SIGNATURE: Cindy Dickinson		MEMBER EMAIL: cdickins@scottsbluff.org	
		DATE: 6/16/2016	

REV. 2/6/15

# Memo

**To:** Cindy Dickinson, City Clerk  
**From:** Lynn Garton, Water Reclamation Supervisor  
**CC:** Mark Bohl, Public Works Director  
**Date:** 6/15/16  
**Re:** 2701 West 42<sup>nd</sup> Street Sewer Call

---

At approximately 10:40pm on Sunday, June 12, 2016, Randy Rutter received a call from the Communication Center concerning a sewer backup at 2701 West 42<sup>nd</sup> Street. Randy contacted Lyle Shapland to come and assist with any cleaning that may need to be done. Randy and Lyle arrived on site at approximately 11:30pm and began investigating the situation. They began by checking manholes from Apple Drive eastward (please see notes and maps) to where the 8 inch line connects to the 15 inch main transmission line just west of 1724 West 42<sup>nd</sup> Street. Most all manholes to the connection of the 15 inch line had standing water caused by the excessive rain from the evening's storm. Water appeared to be flowing extremely fast which indicated no blockage of the line. Most all intersections along the West 42<sup>nd</sup> Street stretch where under water from the rain, those intersections all have manholes located in the flow line for storm drainage. The excessive amount of rain appeared to be infiltrating the manholes and causing the line to backup. Not much could be done to further investigate until a time when the water could recede. The following morning the collection crew returned to the site and inspected the entire line via closed circuit television. The line appeared to be clean, undamaged and showed no signs of obstruction that would cause a blockage.

With the amount of rainfall in such a short period of time on that Sunday evening it is our determination that the rain infiltrated the sanitary sewer line at the manholes in the intersections causing the line to be at its maximum capacity and restricting normal flow from residential properties until the flow of rain water could recede in the mainline.



## Reviewed by Supervisor:

Vork Request: check sewer main line

REMINDER, please do not put work order away until secretary has initialed it after recording.  
Secretary initial here ty Record # 0612161



I Randy Rutter received a call from the Comm Center at 10:40 pm 06-12-16 about a Sewer call at 2701 West 42nd st, the Comm Center informed me that the owner of the home Dave Soule reported that his basement was backing up, I called Mr Soule and he informed me he had water backing up in his basement and that 2 other neighbors were having the same problem, I told Mr Soule that I would be there shortly, I called Lyle Shapland for assistance and he met me at the plant to get the Sewer truck. When Lyle arrived we proceeded to call location and began checking manholes from apple ave to 1724 West 42nd, found standing water in manholes between these locations, the manhole at 1724 West 42d st had heavy flow, we could not check manhole on birch ave because there was a large area of water covering it due to the heavy rain that evening, Lyle and I determined that there wasn't any blockage in the main, it was overloaded from the heavy rain and would take sometime for the water level to go down, we informed Mr Soule and additional neighbors that there was nothing we could do but wait for the level to go down, we informed the home owners that a crew would be back to check the line again first thing in the morning.

Randy D Rutter

City of Scottsbluff  
 2525 Circle Drive  
 Scottsbluff, NE 69361  
 Phone: 308-630-6291



## Project Summary

### SEWER CALLS

Main ID	Date	Address	Start MH	Finish MH	Pipe	Asset length	Surveyed Length
Sewer Call 2701 W 42nd St	6/13/2016	2701 W 42nd St	1007	1006	Clay	344.0	344.0
Sewer Call 2701 W 42nd St_2	6/13/2016	2701 W 42nd St	1007	1008	Clay	335.7	335.7
Sewer Call 2701 W 42nd St_3	6/13/2016	2701 W 42nd St	1008	1068	Clay	282.0	282.0
Sewer Call 2701 W 42nd_4	6/13/2016	2701 W 42nd St	1068	1065	Clay	331.3	331.3
Sewer Call 2701 W 42nd St_5	6/13/2016	2701 W 42nd Ave	1077	1065	Clay	331.0	331.0
Sewer Call 2701 W 42nd St_6	6/13/2016	2701 W 42nd St	1077	1078	Clay	358.0	358.0
Sewer Call 2701 W 42nd St_7	6/13/2016	2701 W 42nd St	1078	1079	Clay	345.5	345.5
Sewer Call 2701 W 42nd St_8	6/14/2016	2701 W 42nd St	1080	1079	Clay	47.6	47.6
Sewer Call 2701 W 42nd St_9	6/14/2016	2701 W 42nd St	1080	1045	Clay	348.8	348.8

Number of inspections: 9

**Subtotal** 2,723.9 ft 2,723.9 ft

Project Summary


Wednesday, June 15, 2016 1:02 PM

Page 1 of 1




# City of Scottsbluff Wastewater Collection System
















CUES, Inc.  
 3600 Rio Vista Avenue  
 Orlando, FL 32805  
 Phone: 407-849-0190  
 Fax: 407-425-1569




## GraniteXP Observation Report with Still Images

Mainline ID: Sewer Call 2701 W 42nd St		Project Name: SEWER CALLS		Start date/time: 6/13/2016 9:22:17 AM		Weather: Dry		Operator: E.S.	
Upstream node: 1006		Downstream node: 1007		Asset length: 344.0					
Comments									

### Observations

Distance	Length	Code	Reversed	Clock Pos.	Severity	Comment
36.9		Lateral Live	Yes	3 /	Live	2701 W 42nd Lateral



Observations with Large Images

Monday, June 13, 2016 9:33 AM

Page 1 of 1



CUES, Inc.  
 3600 Rio Vista Avenue  
 Orlando, FL 32805  
 Phone: 407-849-0190  
 Fax: 407-425-1569




## GraniteXP Observation Report with Still Images

Mainline ID: Sewer Call 2701 W 42nd St	Project Name: SEWER CALLS	Start date/time: 6/13/2016 9:22:17 AM	Weather: Dry	Operator: E.S.
Upstream node: 1006	Downstream node: 1007	Asset length: 344.0		
Comments				

### Observations

Distance	Length	Code	Reversed	Clock Pos.	Severity	Comment
36.9		Lateral Live	Yes	3 /	Live	2701 W 42nd Lateral



Observations with Large Images

Monday, June 13, 2016 9:34 AM

Page 1 of 1

CUES, Inc.  
 3600 Rio Vista Avenue  
 Orlando, FL 32805  
 Phone: 407-849-0190  
 Fax: 407-425-1569




## GraniteXP Observation Report with Still Images

Mainline ID: Sewer Call 2701 W 42nd St		Project Name: SEWER CALLS		Start date/time: 6/13/2016 9:22:17 AM		Weather: Dry		Operator: E.S.	
Upstream node: 1006		Downstream node: 1007		Asset length: 344.0					
Comments									

### Observations

Distance	Length	Code	Reversed	Clock Pos.	Severity	Comment
133.5		Lateral Live	Yes	3 /	Live	2709 W 42nd Lateral





CUES, Inc.  
 3600 Rio Vista Avenue  
 Orlando, FL 32805  
 Phone: 407-849-0190  
 Fax: 407-425-1569




## GraniteXP Observation Report with Still Images

Mainline ID: Sewer Call 2701 W 42nd St	Project Name: SEWER CALLS	Start date/time: 6/13/2016 9:22:17 AM	Weather: Dry	Operator: E.S.
Upstream node: 1006	Downstream node: 1007	Asset length: 344.0		
Comments				

### Observations

Distance	Length	Code	Reversed	Clock Pos.	Severity	Comment
133.5		Lateral Live	Yes	3 /	Live	2709 W 42nd Lateral



Observations with Large Images

Monday, June 13, 2016 9:36 AM

Page 1 of 1



CUES, Inc.  
 3600 Rio Vista Avenue  
 Orlando, FL 32805  
 Phone: 407-849-0190  
 Fax: 407-425-1569




## GraniteXP Observation Report with Still Images

Mainline ID: Sewer Call 2701 W 42nd St		Project Name: SEWER CALLS		Start date/time: 6/13/2016 9:22:17 AM		Weather: Dry		Operator: E.S.	
Upstream node: 1006		Downstream node: 1007		Asset length: 344.0					
Comments									

### Observations

Distance	Length	Code	Reversed	Clock Pos.	Severity	Comment
221.9		Lateral Live	Yes	4 /	Live	2717 W. 42nd St Lateral



Observations with Large Images

Monday, June 13, 2016 9:39 AM

Page 1 of 1

CUES, Inc.  
 3600 Rio Vista Avenue  
 Orlando, FL 32805  
 Phone: 407-849-0190  
 Fax: 407-425-1569




## GraniteXP Observation Report with Still Images

Mainline ID: Sewer Call 2701 W 42nd St	Project Name: SEWER CALLS	Start date/time: 6/13/2016 9:22:17 AM	Weather: Dry	Operator: E.S.
Upstream node: 1006	Downstream node: 1007	Asset length: 344.0		
Comments				

### Observations

Distance	Length	Code	Reversed	Clock Pos.	Severity	Comment
221.9		Lateral Live	Yes	4 /	Live	2717 W. 42nd St Lateral



Observations with Large Images

Monday, June 13, 2016 9:39 AM

Page 1 of 1