

City of Seward, NE

Tuesday, April 5, 2016

Regular Session

Item G11

CONSIDERATION OF APPROVAL TO ADVERTISE FOR BIDS TO POWER WASH, INSPECT AND PAINT THE INTERIOR AND EXTERIOR OF THE NORTH WATER TOWER - Tim Richtig

Administrative Report: Per Department of Health and Human Services rules, the water tower needs to be inspected and cleaned every five years. The last cleaning was in 2010. The plan is to complete this work in the 2016-2017 budget year (October, 2016).

Following review and discussion, a motion to authorize the City to advertise for bids would be appropriate.

Staff Contact:



March 28, 2016

City of Seward
Attn: Mr. Bruce Smith
P.O. Box 38
Seward, Nebraska 68434-0038

Re: Seward Water Tower Rehabilitation
Seward, Nebraska - 2016
Olsson Project No. 016-0511

Dear Mr. Smith:

Design is presently underway for the above referenced project, which will include a complete blast, prime, re-coat of the interior and a power wash and overcoat of the exterior of Seward's existing 750,000 Gallon Water Tower. The preliminary estimate for the base project, based upon information from both recently bid projects and coatings suppliers, is \$300,000. The bid will include alternate bid items for repairs to the overflow system and an exterior logo, in addition to the base bid.

This letter shall serve as a request for permission to bid the project once approval has been obtained from the Nebraska State Department of Health and Human Services (NDHHS).

Please feel free to contact us with any additional questions that you may have.

Sincerely,

A handwritten signature in blue ink that reads 'Owen Killham'.

Owen Killham, PE

Encls.

cc: Bonnie Otte, City of Seward
Tim Richtig, City of Seward

F:\2016\0501-1000\016-0511\20-MANAGEMENT\COMMUNICATION\16-03-28_PBIN_PERMISSION TO BID PROJECT.DOC

601 P Street, Suite 200
P.O. Box 84608
Lincoln, NE 68508-2303

TEL 402.474.6311
FAX 402.474.5160

www.olssonassociates.com