

City of Seward, NE
Tuesday, July 5, 2016
Regular Session

Item G5

**CONSIDERATION OF A WELL PERMIT APPLICATION FOR
MARK JAMES BLANCO II, 2241 NO 2ND - Bruce Smith**

Administrative Report: Following review and discussion, a motion for approval or denial would be in order.

Staff Contact:

**CITY OF SEWARD, NEBRASKA
APPLICATION FOR A WELL PERMIT**

Date: 6/15 2016

Permit No.: _____

Applicant: MARK JAMES BIANCO II

Legal description of property well is to be located on:

Address: 2241 No 2ND
SEWARD, NE. 68434

LOT 2^D, SEWARD HEIGHTS
FIFTH ADDITION, CITY OF SEWARD

Intended Use of Well Water: LAWN & GARDEN

Proposed Depth of Well: 80'


Size and Type of Casing: 4" SCH. 40 PVC

Pumping Equipment: SUBMERSIBLE

Well Driller's Name and Address: EARNEST WELL DRILLING

2796 W. MILFORD RD. MILFORD, NE. 68405

SITE PLAN W



By my signature, as affixed below, I/We hereby assure and/or understand:

- 1) Any permits required by the State of Nebraska and the Upper Big Blue Natural Resource District be submitted prior to issuance of a permit by the City.
- 2) That the well driller shall contact the Water/Wastewater Superintendent at 643-3433, twenty-four (24) hours in advanced of drilling, for final approval of location:
- 3) That the well shall be installed in accordance with the rules and regulations of the state of Nebraska and updates as they become available.
- 4) a) No well shall be located within twenty-five feet (25') of any sewer line, private or public.
b) No well shall be located within fifty feet (50') of any septic tank.
c) No well shall be located within one hundred feet (100') of any disposal field.
d) No well shall be located within twenty-five feet (25') of any water line, private or public.
e) No well shall be located closer than five (5) feet to any property line.
f) No well shall be installed in any easement on the property.
- 5) Assurance that the property owner will install and maintain proper backflow prevention devices as prescribed in section 3-140 of the City of Seward Code, if required.
- 6) That all outside spigots connected to a private well shall have a sign attached, reading ("NOT SAFE FOR DRINKING")
- 7) No water from the private well shall be used for domestic purposes, but shall be used solely for lawn irrigation and garden irrigation or for water used in heating and cooling equipment. Disposal of water for heating or cooling shall be through reinjection back to the same level of aquifer, except that during the spring, summer and fall months such water used for heating or cooling may be used for irrigation of lawn or garden.
- 8) That water to be pumped from the private well, if approved, shall be used exclusively on the legally described property.
- 9) That a well log (drilling record) shall be completed as the well is being drilled, a copy of which will be filled with the Water/Wastewater superintendent.
- 10) That the Water/Wastewater Superintendent or his representative may inspect the well and all connections thereto anytime during construction and anytime thereafter.
- 11) No water from the private well shall be allowed to run off into a City Storm Water Sewer.
- 12) Every well driller, before doing business in the City, shall be registered with the City. Registration forms may be obtained from City Building Inspector.

6-29-2016

Date Approved

[Signature]
Applicant's Signature

By

[Signature]
Water/Wastewater Superintendent

By

Mayor

Date Approved